

EC CONFORMITY DECLARATION

The Company SCHNEIDER ELECTRIC INDUSTRIES S A, 35 RUE JOSEPH MONIER

92500 RUEIL MALMAISON FRANCE

Declares that the product:

Polyester reinforced with glass fiber enclosures **NSYPLM** with and without suffix **T, V or TV**

NSYPLM3025, NSYPLM43, NSYPLM54, NSYPLM64, NSYPLM75, NSYPLM86, NSYPLM108,

NSYPLM3025T, NSYPLM43T, NSYPLM54T, NSYPLM64T, NSYPLM75T, NSYPLM86T, NSYPLM108T

NSYPLM43V, NSYPLM54V, NSYPLM64V, NSYPLM75V, NSYPLM86V, NSYPLM108V,

NSYPLM43TV, NSYPLM54TV, NSYPLM64TV, NSYPLM75TV, NSYPLM86TV, NSYPLM108TV

Provided that it is installed, maintained and used in the application for which it is made, with respect of the "professional practices", relevant installation and manufacturer's instructions.

Complies with the safety provisions for people and things required by the following Council Directives:

2006/95/CE *Low voltage* **89/106/CE - 93/68/CE** *Construction*

Complies with the provisions of the following standards:

IEC 62208 : Empty enclosures for low-voltage switchgear and control gear assemblies. General requirement.

IEC 60529 : Degrees of protection provided by enclosures **IP-66**.

IEC 62262: Degrees of protection provided by **enclosures** against external mechanical impacts **IK-10**. Degree

Protection Glass models (suffix T) IK-08.

IEC 60.695-2-10: Self-extinguish Incandescent wire: Polyester 960°C, lock and gasket 650°C.

IEC 60.695-11-10: Self-extinguish class HB40.

IEC 61.439-1: Low-voltage switchgear and control gear assemblies, are conform to the specification of the

section of double insulation. (Class II, according with IEC 60.364-4-41)

Additional information:

External certifications: Underwriters Laboratories, Bureau Veritas. (Except the models NSYPLM....V and TV)

According to : Reach and RoHs European directives.

This product is intended to be installed, maintained and used by professional persons.

In the case of it is incorporated into an equipment submitted to the Directive 2006/42/CE and its modifications (Machinery Directive), this machinery must not be put into service until it has been declared to conform to the provisions of the Directive.

Year of affixing "CE" marking (ancient denomination)

Year of affixing "CE" marking (NSYPLM series, new denomination)

1999 2010

27th February 2012

Imanol REGO

Universal Enclosures Director **Schneider Electric Industries**