



EG - Konformitätserklärung

Dokument Nr.: 2005
Monat . Jahr: 09.96

Hersteller: WAGO Kontakttechnik GmbH

Adresse: Hansastraße 27
32423 Minden
Deutschland

Produktbezeichnung: **Verbindungs Dosenklemme
Baureihe 273**

Das bezeichnete Produkt erfüllt die Bestimmungen der Richtlinie

Nummer: 73 / 23 / EEC (Niederspannungsrichtlinie)

Text: Richtlinie des Rates zur Angleichung der Rechtsvorschriften der Mitgliedsstaaten betreffend elektrische Betriebsmittel zur Verwendung innerhalb bestimmter Spannungsgrenzen

Die Übereinstimmung des bezeichneten Produktes mit den Bestimmungen der Richtlinie wird durch die vollständige Einhaltung folgender Normen nachgewiesen:

DIN EN 60 998-2-2: Verbindungsmaterial für Niederspannungs-Stromkreise für Haushalt und ähnliche Zwecke
Teil 2-2: Besondere Anforderungen für Verbindungsmaterial als selbständige Betriebsmittel mit schraubenlosen Klemmstellen

Aussteller: WAGO Kontakttechnik GmbH
Hansastraße 27
32423 Minden
Deutschland

Ort, Datum: Minden, den 6. September 1996

Rechtsverbindliche Unterschrift:

L.-R. Hennemann
Technischer Leiter

Anlage

CENELEC CERTIFICATION AGREEMENT

Accord de Certification du CENELEC • CCA • CENELEC-Zertifizierungs-Abkommen

NOTIFICATION OF TEST RESULTS

Product **Connection Clamps (Screwless)**

Tested by request of **WAGO Kontakttechnik GmbH.,
Postfach 2880, D-32385 Minden, Germany.**

Manufactured at (name and place) **as above**

Rating and principal characteristics **1.5 mm², 17.5 A, 400 V, 2.5 mm², 24 A, 400 V,
4 mm², 32 A, 400V.**

Trade mark (if any) **WAGO**

Model/Type Ref. **273-... (see the relevant test report)**

Additional information (if any) **This product is covered by the license of the ®-mark.**

A sample of the product has been tested and found to be in conformity with the current HD/EN and equivalent national standard (number and edition):

EN 60998-2-2 1993.

as shown in the test report (reference No.) **119663/-01, /-02, /-03.**

This Notification of Test Results is the result of testing a sample of the product submitted, in accordance with the provisions of the relevant specific standard.

This notification of Test Results has been established by a body which participates in the CENELEC Certification Agreement (CCA) of 11th September 1973 as amended on 29th March 1983. Any other body participating in the CCA will take this Notification as a basis for granting a national mark of conformity or a national approval as specified in the CCA, as long as the standard referred to above is still in force in the country of that body. This Notification of Test Results may be challenged if it is more than 3 years old.

Date **1996-01-08** Signature _____

PO box 514, Lyskaer 8
DK 2730 Herlev • Denmark
Telephone +45 44 94 72 66
Telefax + 45 44 94 72 61

Internal Ref. **B. Ostermann.**

DEMKO
Testing and Certification